

---

**From:** McAteer, Mike  
**Sent:** Thursday, August 31, 2017 6:04 PM  
**To:** Smalley, Bryant; Delgado, Eric; Restivo, Angela; Mason, Steve; Buchanan, Kayla  
**Subject:** FW: BWN and Inoperable list for 8/31/2017  
**Attachments:** Harvey BWN 08312017.xlsx; Inoperable PWS and WW 8312017.xlsx

Daily update on Water/WWTP facilities....

Mike McAteer  
Federal On-Scene Coordinator  
U.S. EPA  
1445 Ross Ave  
Suite 1200 (6SF-ER)  
Dallas, Texas 75202  
(214) 354 9371 (mobile)  
(214) 665 7157 (office)  
mcateer.mike@epa.gov

-----Original Message-----

From: Melinda Torres [mailto:Melinda.Torres@tceq.texas.gov]  
Sent: Thursday, August 31, 2017 5:29 PM  
To: emily.falone@hhs.gov; McAteer, Mike <mcateer.mike@epa.gov>; andrea.k.ruminski@usace.army.mil;  
cory.s.koger@usace.army.mil; Waite, Andrew <Waite.Andrew@epa.gov>; dshs@soc.texas.gov  
Subject: BWN and Inoperable list for 8/31/2017

Sorry for the delay.

Melinda

Melinda Torres  
Assistant Homeland Security Coordinator  
Critical Infrastructure Division  
Texas Commission on Environmental Quality  
512-466-2580

## BWN Summary

Active	166
Rescinded	44
Total	210

## Hurricane Harvey Boil Water Notice Tracking- 2017

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
HARRIS	1012806	Alton Theiss Subdivision	45	14	8/28/2017	SWIFT Reverse 911.	No access
HARRIS	1011687	Atascocita Acres Subdivision	381	128	8/28/2017	SWIFT Reverse 911.	
HARRIS	1010809	Bammel Oaks Estates No 1	33	13	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
HARRIS	1010810	Bammel Oaks Estates No 2	234	80	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
Harris	1010098	Beaumont Place	2082	694	8/26/2017		Hurricane
Liberty	1460175	Bella Vista	657	219	8/26/2017		Hurricane
HARRIS	1010099	Bergville Addition	27	10	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200065	Bernard Acres	228	81	8/28/2017	SWIFT Reverse 911.	No access
HARRIS	1011860	Berry Hill Estates	144	52	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
HARRIS	1011084	Boudreaux Gardens	123	34	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
HARRIS	1011014	Brittmoore Utility Company	2871	827	8/28/2017	SWIFT Reverse 911.	Operational but has low pressure
Brazoria	0200152	Calico Farms	75	23	8/28/2017	SWIFT Reverse 911.	
SAN JACINTO	2040038	Camilla Twin Harbor	554	195	8/30/2017	SWIFT Reverse 911.	8/30; Main Break for small area
Jackson	1200022	Cape Carancahua WSC	1212	404	8/26/2017	Region	Loss of power
Chambers	0360093	Carriage Trails	96	33	8/28/2017	SWIFT Reverse 911.	No access
Liberty	1460102	Cedar Estates	246	258	8/28/2017	SWIFT Reverse 911.	
MONTGOMERY	1700555	Cimarron Country	702	242	8/29/2017	SWIFT Reverse 911.	RUNNING ON GENERATOR POWER
Liberty	1460004	City of Daisetta	1137	403	8/30/2017	Media	loss of pressure
Goliad	0880001	City of Goliad	2025	1056	8/26/2017		No eletricity, generator not working
San Patricio	2050001	City of Gregory	1901	650	8/26/2017		Loss of power

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
San Patricio	2050002	City of Ingleside	9557	3287	8/26/2017	Corpus Region notified	Loss of power
Fayette	0750003	City of La Grange	4793	2323	8/28/2017		Well pumps failed
Jefferson	1230039	City of Nome	753	295	8/28/2017		flooding of monitoring equipment
San Patricio	2050004	City of Odem	2499	1285	8/26/2017		Loss of power
Calhoun	0290002	City of Port Lavaca	12248	5390	8/27/2017		low pressure
Refugio	1960001	City of Refugio	2890	1404	8/29/2017		Storm damage
Aransas	0040002	City of Rockport	26450	10841	8/28/2017		No Grid - No Generator (offline)
San Patricio	2050006	City of Sinton	5657	2368	8/26/2017		Loss of power
Victoria	2350002	City of Victoria	62592	31853	8/24/2017	Media	Loss of power
Montgomery	1700304	City of Wood Branch Village	1476	492	8/28/2017	Media	Flood damage
ANGELINA	0030030	City of Zavalla	710	434	8/29/2017	Media	line break
HARRIS	1010116	Colonial Hills	930	311	8/28/2017	SWIFT Reverse 911.	UNABLE TO ACCESS SITE DUE TO FLOOD WATERS BUT CUSTOMERS HAVE WATER.
HARRIS	1013189	Country Club Green	405	138	8/27/2017	SWIFT Reverse 911.	BACK ON NORMAL POWER WATER ON.
Brazoria	0200337	Country Creek Estates	198	71	8/28/2017	SWIFT Reverse 911.	
Jefferson	1230037	Country Side Estates	1176	425	8/28/2017	SWIFT Reverse 911.	No access
HARRIS	1013296	Cypress Creek Ranch	273	91	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
Polk	1870126	Dallardsville Segno WSC	613	246	8/28/2017		line breaks during flooding
Liberty	1460141	Dayton Creek Water System	225	22	8/28/2017	SWIFT Reverse 911.	No access
Liberty	1460136	Dayton Oaks Estate	216	72	8/28/2017	SWIFT Reverse 911.	
MONTGOMERY	1700129	Dogwood Hills	927	317	8/28/2017	SWIFT Reverse 911.	8/30; Operational and waiting on special samples
HARRIS	1010122	Dorsett Place	42	15	8/28/2017	SWIFT Reverse 911.	8/30; Unknown

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
Jim Wells	1250033	ENGLISH ACRES	90	30	8/26/2017	Reply to TCEQ request from information from Richard Bosch	Hurricane
HARRIS	1013262	Estates of Willow Creek	588	237	8/28/2017	SWIFT Reverse 911.	
Nueces	1780058	Flint Hills Resources	2183	1	8/26/2017		Loss of power
Brazoria	0200153	Flora 6	51	16	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200151	Flora 7	45	15	8/28/2017	SWIFT Reverse 911.	
Fort Bend	0790385	Fulbrook Subdivision Water Plant	660	244	8/28/2017	SWIFT Reverse 911.	
Calhoun	0290007	GBRA Calhoun County Rural Water System	4020	1340	8/27/2017	Region	
Calhoun	0290005	GBRA Port Lavaca	0	8313	8/27/2017	Region	
Liberty	1460179	Grande San Jacinto WS	72	24	8/26/2017		Hurricane
Brazoria	0200349	Heights Country Subd	105	34	8/28/2017	SWIFT Reverse 911.	
HARRIS	1013159	Hunter's Village	90	47	8/28/2017	SWIFT Reverse 911.	No access
HARRIS	1013153	Imperial Valley MHC	450	110	8/28/2017	SWIFT Reverse 911.	
HARRIS	1010068	Industrial Utilites	2500	97	8/28/2017	SWIFT Reverse 911.	TXDOT HAS CLOSED ROADS AND WE CANNOT GET TO THE FACILITIES. 8/30; No access
Tyler	2290010	Ivanhoe Land of Lakes	2055	685	8/30/2017		line break/flood water
HARRIS	1010163	Kenwood Subdivision	156	50	8/28/2017	SWIFT Reverse 911.	Pumps are flooding, no power
HARRIS	1011536	Kitzwood Subdivision	90	32	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
Polk	1870019	Lake Livingston Bass Bay Indian Hill 1	132	44	8/28/2017		Flooding / Electrical failure

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
Liberty	1460025	Lake Livingston Big Thicket Lake 1	228	76	8/28/2017		Flooding / Electrical failure
San Jacinto	2040026	Lake Livingston Cozy Forest	166	58	8/28/2017		Flooding / Electrical failure
Polk	1870027	Lake Livingston Estates 4&5	627	209	8/28/2017		Flooding / Electrical failure
Polk	1870068	Lake Livingston Forest Hills Water	359	147	8/28/2017		Flooding / Electrical failure
Polk	1870020	Lake Livingston Indian Hills 2 Water	627	252	8/28/2017		Flooding / Electrical failure
Polk	1870013	Lake Livingston Nugents Cove	469	194	8/28/2017		Flooding / Electrical failure
Polk	1870025	Lake Livingston Pineshadows	1811	742	8/28/2017		Flooding / Electrical failure
Polk	1870166	Lake Livingston Pineshadows East	0	5313	8/28/2017		Flooding / Electrical failure
Fort Bend	0790423	Lakes of Mission Grove	138	84	8/28/2017	SWIFT Reverse 911.	
HARRIS	1013050	Lakes of Rosehill Water System	1242	411	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
Brazoria	0200067	Las Playas	321	114	8/28/2017	SWIFT Reverse 911.	
Montgomery	1700039	Lazy River Improvement District	788	220	8/29/2017		Hurricane
Chambers	0360081	Leaning Oaks	102	31	8/28/2017	SWIFT Reverse 911.	No access
Liberty	1460012	Liberty County FWSD 1 Hull	1020	340	8/30/2017	Media	low pressure
Matagorda	1610129	Live Oak Landing Subdivision	39	13	8/26/2017	Direct delivery	loss of power

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
Jim Wells	1250039	LOMA LINDA WATER SUPPLY	144	48	8/26/2017	Reply to TCEQ request from information from Richard Bosch	Hurricane
Brazoria	0200347	Meadowland Subdivision	351	118	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200271	Meadowlark Subdivision	105	31	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200189	Meadowview Subdivision	129	43	8/28/2017	SWIFT Reverse 911.	
HARRIS	1010288	Mobile Home Estates	543	181	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
MONTGOMERY	1700773	Montgomery Co MUD 119 Spring Trails	3126	909	8/29/2017		well failure
Brazoria	0200226	Mooreland Subdivision Blk 1 & 2	156	56	8/28/2017	SWIFT Reverse 911.	8/30; Flood Water Around Well
Brazoria	0200227	Mooreland Subdivision Blk 3 & 4	93	30	8/28/2017	SWIFT Reverse 911.	8/30; Flood Water Around Well at TX0200226, systems are interconnected
Brazoria	0200146	Oak Bend Estates	165	55	8/28/2017	SWIFT Reverse 911.	
Matagorda	1610031	Oak Hollow Subdivision	72	24	8/28/2017	SWIFT Reverse 911.	
Liberty	1460096	Oak Meadows II	105	35	8/28/2017	SWIFT Reverse 911.	No access
Liberty	1460100	Oak Meadows Subdivision II & III	246	46	8/28/2017	SWIFT Reverse 911.	No access
Brazoria	0200242	Palmetto Subdivision	120	42	8/28/2017	SWIFT Reverse 911.	No access
HARRIS	1013041	Park Forest Water System	210	70	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
Waller	2370005	Pattison WSC	1461	30	8/28/2017	Media	Power outage
HARRIS	1011955	Peek Road Utilities	483	160	8/28/2017	SWIFT Reverse 911.	No access

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
HARRIS	1010535	Pine Trails Utility Company Inc.	6969	2323	8/28/2017	SWIFT Reverse 911.	UNABLE TO ACCESS SITE DUE TO FLOOD WATERS BUT CUSTOMERS HAVE WATER, 8/30; generator is down.
Polk	1870130	Pinwah Pines Estates	130	54	8/29/2017	direct delivery	Line break of provider
Chambers	0360096	Plantation on Cotton Bayou	1497	502	8/28/2017	SWIFT Reverse 911.	TXDOT HAS CLOSED ROADS AND WE CANNOT GET TO THE FACILITIES.
Brazoria	0200223	Pleasant Meadows Subd	84	26	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200248	Pleasantdale Subd	48	17	8/28/2017	SWIFT Reverse 911.	
Calhoun	0290065	Port Oconnor Improvement District	1250	1673	8/26/2017		Loss of power
Wharton	2410010	Pyssen's Live Oak Estates	138	46	8/28/2017	SWIFT Reverse 911.	No access
Brazoria	0200219	Quail Meadows Subd	108	37	8/26/2017	SWIFT Reverse 911.	EMERGENCY GENERATOR INSTALLED AND PLANT BACK ON WITH GENERATOR POWER. WE WILL NOT BE ABLE TO REFUEL SITE DUE TO ROAD AND HIGHWAY FLOODING. SCOT WORKING ON SWIFT REACH TO NOTIFY CUSTOMER THEY WILL LOSE WATER SERVICE ONCE GENERATOR RUNS OUT OF FUEL.
Liberty	1460178	Rancho San Vicente	96	32	8/26/2017		Hurricane
Fort Bend	0790405	Riverwood Forest	678	240	8/28/2017	SWIFT Reverse 911.	No access



County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
Fort Bend	0790396	Rose Meadows III	435	215	8/26/2017	SWIFT Reverse 911.	SERVICE LINE LEAK REPAIRED PRESSURE BACK TO NORMAL. AREA IS FLOODED BUT STILL ACCESSABLE. 8/30; No access
San Patricio	2050010	Saint Paul WSC	450	185	8/27/2017		Loss of power
San Patricio	2050011	San Patricio County Municipal Water District	225	33499	8/25/2017		Loss of power
Brazoria	0200255	Sandy Ridge Subd	60	22	8/28/2017	SWIFT Reverse 911.	No access
Fort Bend	0790389	Shadow Grove	111	37	8/28/2017	SWIFT Reverse 911.	No access
Brazoria	0200258	Sharondale Subd	87	30	8/28/2017	SWIFT Reverse 911.	
Liberty	1460115	South Dayton Oaks	69	23	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200415	South Meadows East	360	120	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200413	South Meadows West	87	145	8/28/2017	SWIFT Reverse 911.	
Bee	0130016	South Texas Children's Home	150	29	8/25/2017		Loss of power
HARRIS	1013103	Stable Gates	744	248	8/28/2017	SWIFT Reverse 911.	8/30; Unknown
Brazoria	0200363	Sterling Estates	105	31	8/28/2017	SWIFT Reverse 911.	
HARRIS	1010216	Stetner Addition	135	48	8/28/2017	SWIFT Reverse 911.	
HARRIS	1013187	Summer Lake Ranch	465	156	8/26/2017	SWIFT Reverse 911.	POWER RESTORED BACK TO NORMAL POWER, 8/30; ordering samples
Jefferson	1230083	Sunchase Subdivision	104	42	8/28/2017	SWIFT Reverse 911.	No access
Jackson	1200037	Sunrise Bay Subdivision	33	11	8/26/2017	Direct delivery	Loss of power
Aransas	0040055	Sunset Bay	45	15	8/26/2017	Direct delivery	Loss of power
HARRIS	1011865	Tasfield	219	68	8/28/2017	SWIFT Reverse 911.	

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
Matagorda	1610033	Tidewater Oaks Subd	234	66	8/28/2017	SWIFT Reverse 911.	
Liberty	1460145	Towering Oaks I	127	45	8/28/2017	SWIFT Reverse 911.	No access
Polk	1960003	Town of Woodsboro	1494	746	8/28/2017		Hurricane
Matagorda	1610017	Tres Palacious Oaks Subd	603	196	8/28/2017	SWIFT Reverse 911.	No access
Chambers	0360084	Trinity Cove	96	32	8/28/2017	SWIFT Reverse 911.	TXDOT HAS CLOSED ROADS AND WE CANNOT GET TO THE FACILITIES.
Brazoria	0200024	Wagon Wheel Utility Company	309	97	8/26/2017	SWIFT Reverse 911.	BOOSTER PUMPS TRIPPED AND STARTER WENT OUT DUE TO POWER SURGE CONTRACTOR REPLACED STARTED AND GOT BOOSTER PUMPS BACK UP.
HARRIS	1013195	Walraven Subdivision	198	66	8/28/2017	SWIFT Reverse 911.	No Power
Matagorda	1610137	Waypoint Landing	33	11	8/26/2017	Direct delivery	Loss of power
Brazoria	0200211	Wellborn Acres	51	18	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200254	Westwood Subd	84	28	8/28/2017	SWIFT Reverse 911.	
Brazoria	0200019	Weybridge SUBD	87	29	8/28/2017		No access
HARRIS	1013570	Willow Creek Industrial Park	24	1	8/28/2017	SWIFT Reverse 911.	
MONTGOMERY	1700321	Wilshire Subdivision	240	82	8/26/2017	SWIFT Reverse 911.	WELL PUMP WENT OUT 8/25/2017 PUMP CHANGED OUT AT 2:00AM 8/26/2017. 8/30 samples ordered
Brazoria	0200229	Windsong Subd	129	44	8/28/2017	SWIFT Reverse 911.	

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
MONTGOMERY	1700657	Woodland Ranch	294	110	8/28/2017	SWIFT Reverse 911.	TREE FELL ONTO WELL HOUSE AND SWITCHED OFF THE POWER DISCONNECT LEVER. LEVER SWITCHED BACK ON AND POWER AND WATER BACK ON.
Liberty	1460093	Woodridge Park Subdivision	135	45	8/28/2017		loss of pressure
Liberty	1460091	Woodway Subdivision WS	924	308	8/28/2017		loss of pressure
Liberty	1460163	Cedar Creek WS	900	300	8/28/2017		loss of pressure
Harris	1010494	Lake Forest Utility District	6291	2073	8/29/2017		loss of pressure/flooding
Montgomery	1700652	Pine Knob Subdivision	39	13	8/29/2017		Power outage
Liberty	1460150	Southern Oaks WS	99	33	8/29/2017		Power outage
Wilson	2470020	Lake Valley Water	456	152	8/27/2017		Power outage
Montgomery	1700318	Coe Country	39	13	8/30/2017		Power outage
Brazoria	0200656	Chenango Ranch	51	17	8/26/2017		Hurricane
Brazoria	0200616	Suncreek Ranch Section 2	195	65	8/26/2017		Hurricane
San Patricio	2050007	City of Taft	4560	1520	8/27/2017		Loss of pwer and pressure
Calhoun	0290071	La Salle WCID 1-A	261	87	8/27/2017		Loss of pressure
Calhoun	0290065	Port Oconnor Improvement District	1250	1673	8/27/2017		Loss of pressure
Montgomery	1700208	Washington County Railroad	648	216	8/29/2017		Loss of pressure
Polk	1870136	Coutry Sunrise	144	59	8/28/2017		Loss of pressure
Polk	1870123	Goodrich North	216	72	8/28/2017		Loss of Pressure

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Method of Delivery***	BWN Reason- *** Many reports are being received through non-traditional reporting and lack all details.
Calhoun	0290003	Union Carbide Seadrift Plant	683	150	8/29/2017		Loss of Pressure
Jefferson	1230004	Meeker MWD	2864	1132	8/30/2017		Hurricane
Hardin	1000053	Big Thicket Retreat	95	36	8/30/2017		Loss of pressure
San Jacinto	2040034	Lake Livingston Flowing Wells	133	46	8/30/2017		Loss of pressure
Liberty	1460144	Old Snake River Estates West	42	14	8/30/2017		Loss of pressure
Liberty	1460027	Hoop N Holler Lake Estates	282	100	8/30/2017		Loss of Pressure
Liberty	1460036	Lake Livingston New River Lake Estates	132	44	8/30/2017		Loss of Pressure
Liberty	1460143	Horseshoe Lake Estates Sunset	111	37	8/30/2017		Loss of Pressure
Liberty	1460014	Sam Houston Lake Estates 1	81	27	8/30/2017		Loss of Pressure
Polk	1870051	Lake Livingston Wilson Lake Estates	167	67	8/30/2017		Loss of Pressure
Harris	1010501	Harris County Utility District 6	7410	2470	8/30/2017		Loss of Pressure
Galveston	0840044	Bolivar Peninsula SUD	12924	5024	8/30/2017		Loss of Pressure
Jefferson	1230086	Northwest Forest MUD	615	243	8/31/2017		Loss of Pressure
Bee	0130016	South Texas Children's Home	150	29	8/26/2017	Media	Loss of Pressure
Hardin	1000070	Ranchland	40	15	8/31/2017		Loss of Pressure
Harris	1011461	Red Dot South RV Park	114	38	8/31/2017		Power outage
Harris	1010494	Lake Forest Utility District	6291	2073	8/29/2017	Radio	Loss of Pressure
Brazos	0210016	Wellborn SUD	19068	7627	8/30/2017	Direct	Line Break

### Hurricane Harvey Rescinded Boil Water Notice Tracking- 2017

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	Rescind/ Start-up Date	Method of Delivery	BWN/Shutdown Reason
Nueces	1780003	City of Corpus Christi	325733	96750	8/25/2017	8/27/17 (main system) 8/28/17 Island	News media/radio and reverse 911	Loss of SCADA, unable to determine quality
Karnes	1280002	City of Kenedy	6760	3528	8/26/2017	8/29/2017	Media	Loss of power
San Patricio	2050005	City of Portland	19186	7961	8/27/2017	8/30/2017	Region	
Live Oak	1490017	Lake Vista Utility Company	708	236	8/25/2017	8/28/2017	auto dial and text messages	Loss of power
HARRIS	1010011	Greenwood Village	2436	807	8/28/2017	8/30/2017	SWIFT Reverse 911.	UNABLE TO ACCESS SITE DUE TO FLOOD WATERS BUT CUSTOMERS HAVE WATER.
HARRIS	1010092	Aldine Meadows	219	74	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
HARRIS	1010100	Mary Francis Subdivision	1659	566	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
HARRIS	1010334	Spring Creek Forest	117	40	8/28/2017	8/30/2017	SWIFT Reverse 911.	System found to be okay
HARRIS	1011633	Oak Manor	102	37	8/28/2017	8/30/2017	SWIFT Reverse 911.	System found to be okay
HARRIS	1013127	Fairway Crossing	645	207	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
HARRIS	1013144	Classic Pines	249	94	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
Liberty	1460033	Maywood Acres	129	44	8/28/2017	8/30/2017	SWIFT Reverse 911.	System found to be okay
Liberty	1460137	Webb Way	43	14	8/28/2017	8/30/2017	SWIFT Reverse 911.	System found to be okay

MONTGOMERY	1700006	Airport Heights	45	15	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
MONTGOMERY	1700015	Laird Estates	51	17	8/28/2017	8/30/2017	SWIFT Reverse 911.	System found to be okay
MONTGOMERY	1700061	Piney Point	225	76	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
MONTGOMERY	1700096	Crystal Forest Subdivision	543	195	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
MONTGOMERY	1700264	Deerwood Subdivision	1116	405	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
MONTGOMERY	1700324	Huntington Estates	405	132	8/28/2017	8/30/2017	SWIFT Reverse 911.	Staff were able to visit the site and confirm normal plant operation.
MONTGOMERY	1700702	Estates of Legends Ranch	588	197	8/28/2017	8/30/2017	SWIFT Reverse 911.	System found to be okay
Polk	1870155	Cedar Point	915	408	8/26/2017	8/30/2017	SWIFT Reverse 911.	MAIN BREAK CAUSING LOW PRESSURE. 8/30 Operator lifted BWN
Brazoria	0200190	Centennial Place	96	32	8/28/2017	8/30/2017	SWIFT Reverse 911.	System found to be okay
Harris	1012315	Nottingham Country MUD	6633	2211	8/29/2017	8/30/2017	Media	Flooding of water plant
Brazoria	0200341	Village Trace WS	453	149	8/28/2017	8/30/2017	SWIFT Reverse 911.	System found to be okay
Chambers	0360005	Gray Utility_Veranda	3093	1031	8/28/2017	8/30/2017	SWIFT Reverse 911.	TXDOT HAS CLOSED ROADS AND WE CANNOT GET TO THE FACILITIES. 8/30; Plant found to be okay

Chambers	0360100	Hackberry Creek	165	58	8/28/2017	8/30/2017	SWIFT Reverse 911.	TXDOT HAS CLOSED ROADS AND WE CANNOT GET TO THE FACILITIES. 8/30; Plant found to be okay
Chambers	0360122	Barrows Ranch	564	192	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant found to be okay
Fort Bend	0790261	Astro_Niagra	165	55	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant found to be okay
Grimes	0930042	West Magnolia Forest	93	32	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
HARRIS	1011647	Creeside Estates South	366	123	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
HARRIS	1013089	Heron Lakes	2658	892	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700078	Pine Vista MH Village	210	71	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700128	Walnut Springs	534	192	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700216	Oakwood Acres	225	74	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700287	Turtle Creek	507	175	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700330	Decker Woods Subdivision	636	221	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700437	Clear Creek Forest Section 12	1611	560	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700529	Lake Creek Forest	753	250	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700601	Brushy Creek Utility Inc	330	115	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700641	Timberloch Estates	645	223	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700651	Indigo Ranch	345	118	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700665	Greenfield Forest	1485	495	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating
MONTGOMERY	1700670	White Oak Ranch	177	62	8/28/2017	8/30/2017	SWIFT Reverse 911.	Plant is accessible and operating

Walker	2360010	Superior Water Works SUD Riverside	5760	1920	8/29/2017	8/31/2017	posted	line break/flooding
--------	---------	--	------	------	-----------	-----------	--------	------------------------



<b>Inoperable Summary 8/30/2017</b>	
Drinking Water	61
Wastewater	30
Total	91

## Inoperable Public Drinking Water Systems 8/31/3017

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	BWN/Shutdown Reason
Harris	1010085	Apache Land	177	59	8/27/2017	Complete Outage
Victoria	2350042	ARENOSA CREEK ESTATES	65	26	No Grid - No Generator (offline)	
Montgomery	1700171	Arrowhead Lake_Frontier Lake	957	326	8/29/2017	8/29/2017- Power outage, 8/30 Water is on, ordering samples
Brazoria	0200570	Bayou Shadows WS	150	50	8/28/2017	Flood damage
Harris	1010098	Beaumont Place	2082	694	8/27/2017	Complete Outage
Victoria	2350005	Brentwood_Water	456	152	8/26/2017	POWER IS OUT IN THE AREA ACCORDING TO CUSTOMER WHO STAYED BEHIND AND CONTACTED OPERATOR. POWER WILL BE OUT FOR AN ESTIMATED 5 DAYS. WE WILL HAVE TO GET TEMPORARY GENERATORS OUT THERE ONCE IT IS DEEMED SAFE TO ENTER THE AREA.
Liberty	1460025	BIG THICKET LAKE ESTATES 1	228	76		
Aransas	0040058	Captain Kens RV Park	30	22	8/25/2017	Complete Outage
Polk	1870088	Chesswood WS	102	41	8/28/2017	Flood damage
Jefferson	1230001	City of Beaumont Water UD	130260	49263	8/31/2017	Complete Outage
Refugio	1960001	CITY OF REFUGIO				
Victoria	2350002	CITY OF VICTORIA	62592	31853	Intake Pump issue and generator, generator is onsite 8/27/2017	
Victoria	2350035	COLETO CREEK MOBILE HOME PARK	105	45	No Grid - No Generator (offline), pressure loss	

Inoperable Public Water Systems

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	BWN/Shutdown Reason
Victoria	2350036	COLETO WATER	450	150	No Grid - No Generator (offline), pressure loss	
Aransas	40003	COPANO COVE SUBDIVISION				
Aransas	40017	COPANO HEIGHTS WATER				
Aransas	40029	COPANO RIDGE SUBDIVISION				
Harris	1011651	Cypress Fields Subdivision	441	151	8/28/2017	OPERATOR UNABLE TO ACCESS SITE DUE TO FLOODING. 8/30; Operational, waiting on special samples
Harris	1010254	Cypress Place	147	49	8/28/2017	OPERATOR UNABLE TO ACCESS SITE DUE TO FLOODING. 8/30; System is operational and waiting on special samples
Montgomery	1700040	Enchanted Forest	54	18	8/28/2017	8/30; Power loss
Calhoun	0290007	GBRA Calhoun Co Rural WS	4020	1340	8/25/2017	Water outage/BWN
Calhoun	0290005	GBRA Port Lavaca	0	8313	8/25/2017	Water outage/BWN
Harris	1010501	Harris Co Utility District 6	7410	2470	8/29/2017	Flood damage
Brazoria	0200218	Hastings Homeowners WS	177	60	8/26/2017	POWER POLE BROKEN AND STREETS BLOCKED OFF. ELECTRICIAN UNABLE TO ACCESS SITE TO INSTALL GENERATOR
Liberty	1460085	Huntsman Petrochemical Dayton Facility	50	6	8/28/2017	Storm damage
Liberty	1460164	Indian Springs WS	183	61	8/28/2017	Complete outage
Brazoria	0200401	Key Largo Utilities	28	30	8/30/2017	Complete outage/shutdown
Liberty	1460007	Lake Livingston Big Thicket Lake 2	435	145	8/28/2017	Water outage/BWN
Polk	1870136	Lake Livingston Country Sunrise	144	59	8/28/2017	Storm damage
Polk	1870123	Lake Livingston Goodrich North	216	72	8/28/2017	Storm damage

Inoperable Public Water Systems

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	BWN/Shutdown Reason
Polk	1870067	Lake Livingston Wild Country Lake Estates	466	191	8/28/2017	Storm damage
Wilson	2470020	LAKE VALLEY WATER	456	152	power issues	
Live Oak	1490017	LAKE VISTA UTILITY CO	708	236	No-Grid, generator damaged	
Jefferson	1230004	MEEKER MWD				
Harris	1011510	Mark's Glen Subdivision	258	87	8/28/2017	8/30; Water but no residual NAPCO is responding, a tree took out power
Matagorda	1610052	Matagorda Dunes Subdivision	426	142	8/25/2017	Mandatory Evacuation Notice
Matagorda	1610052	Matagorda Dunes Subdivision	426	142	8/30/2017	Complete Outage
Montgomery	1700773	Montgomery Co MUD 119 Spring Trails	3126	909	8/29/2017	Storm damage
Harris	1010915	North Woods Estates	102	34	8/28/2017	OPERATOR UNABLE TO ACCESS SITE DUE TO FLOODING 8/30; Operational and waiting on special samples
Nueces	1780006	NUECES COUNTY WCID 4	900	300	No Grid - No Generator (offline)	
Waller	2370005	PATTISON WSC	1461	487	Ms Chapa said the system is flooded and can not completely assess the level of damage. Will need follow up in one week to further assess the system's needs.	
Polk	1870055	Oak Terrace Estates WS	302	125	8/29/2017	Flood damage
Brazoria	0200617	Palm Crest	117	74	8/27/2017	NO WATER CALL OPERATORS UNABLE TO GET TO SITE DUE TO HIGHWAY AND ROAD FLOODING.
Polk	1870130	Pinwah Pines Estates	130	54	8/29/2017	Complete outage/shutdown
Calhoun	290027	PORT ALTO HOA DISTRICT 1	115	32	Storm damage	
Calhoun	0290028	Port Alto WSC	115	32	8/25/2017	Storm damage
Harris	1010196	Ralston Acres WSC	330	110	8/28/2017	Storm damage
Montgomery	1700778	Rio Vista Subdivision	117	39	8/27/2017	Storm damage
Harris	1011861	Rolling Oaks	285	91	8/28/2017	8/30; loss of pressure due to power outage, generator recently turned power on

Inoperable Public Water Systems

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	BWN/Shutdown Reason
Harris	1010201	Royalwood MUD	1017	339	8/30/2017	Complete Outage
Calhoun	290054	SEADRIFT COKE PLANT				
Brazoria	200053	SNUG HARBOR SUBDIVISION				
Calhoun	290056	SUNILANDINGS UTILITIES				
Victoria	2350009	THE ESTATES OF SANDY HILLS				
Newton	1760002	Toledo Village WSC	1531	543	8/31/2017	Complete Outage
Calhoun	0290003	Union Carbide Seadrift Plant	683	150	8/29/2017	Plant off-line, restart 8/30/2017
Victoria	2350001	Victoria Co WCID 1	2459	859	8/25/2017	Storm damage
Harris	1010320	Western Trails Subdivision	129	43	8/29/2017	Flood damage
Harris	1010622	Westgate Subdivision	147	49	8/28/2017	8/30; Water is back on, residual good, loss of pressure because of power outage and flooding
HARRIS	1010622	Westgate Subdivision	147	51	8/28/2017	8/30; Water is back on, residual is good, loss of pressure due to power outage, flooding
Brazoria	0200019	Weybridge Subd	87	31	8/28/2017	OPERATOR UNABLE TO ACCESS SITE DUE TO FLOODING.

# Inoperable Wastewater

Inoperable Wastewater Systems 8/31/2017				
WW Name	ID	Issue	County	Contact
Archdioces of Galvestion	14218001	No power	Montgomery	Gloria Bustillo, 281-9007244
Bloomington ISD	14578001	WWTP under water and no water	Victoria	Misty Bransfield, 361-649-6871
Beach Road Mud	13563001	clarifies hit	Matagorda	Emil Krejci, 979-429-7081
Caney Creek	10124004	facility hit by tornado, debris landed on treatment units and caused damages to plant nad generator	Matagorda	Donald Fox, 979-429-1027
City of Austwell	11117001	Do not have fuel for genertor	Refugio	Rene Rodriquez, 361-237-9054
City of Baytown	10395007	under water	Haris	Jerry LeCompte
City of Beeville	10124004	being directed to Moore Street WWTP which is fully operational	Bee	Wayne Shaffer, 361-362-5698
City of Cleveland	10766001	under water	Liberty	Colton Lafromce, 281-223-0650
City of Cleveland	10766002	under water	Liberty	Colton Lafromce, 281-223-0650
City of Conroe	10008002	under water	Montgomery	936-521-5114
City of Gregory	10092001	Roof of control center blown off, need generatorfor WWTP and 2 480v for generators	San Patricio	Abel Sanchez, 361-446-6530
City of Patton Village	15294001	3 lift stations are submerged	Montgomery	Ryan Bobo, 832-318-5348
City of Pearland	10134010	Structue damage, generator not working	Brazoria	Laura Rodriquez, 281-652-1900
City of Pearland	10134002	under water	Brazoria	Laura Rodriquez, 281-652-1900
City of Taft	10705001	Roof damage at WWTP	San Patricio	Joe Sandoval/Hector Lopez 361-533-4616
City of West Columbia	10312001	shut down, entire collection system under water	Brazoria	Terry Elliot, 979-481-3027
Corix Utilities	14404001	power outage	Matagorda	Gloria Bustillo, 281-9007244
Farmers Transport Inc	14823001	Need power	Calhoun	Jesse Wood, 979-637-0010
Forest Glenn	11844001	digester is damaged, lost some activated sludge	Walker	Justin Perrit, 936-295-7641
Harris County WCID 1	10528001	underwater	Harris	Katie Hargoza, 832-709-9029
Harris County WCID 1	10104001	generators or bypass not working	Harris	Mark Taylor, 281-426-2115

# Inoperable Wastewater

WW Name	ID	Issue	County	Contact
Lighthouse RV Park	1593001	not operating	Matagorda	Vernon Budwill, 281-808-8952
Memorial Villages Water Authority	10584001	plant unindated with water	Harris	Micheal Montgomery, 713465-8318
Montgomery County Mud 139	10104001	not operating	Harris	Vernon Budwill, 281-808-8952
Montgomery County Mud 16	11386001	lost power, 4 feet of water	Montgomery	Stephen Woodring, 281-850-7001
Roman Forest Consolidated Mud	13638001	under water	Matagorda	Chris Buerger, 832-966-1132
San Patricio County MUD 1	13644001	No power	San Patricio	Juan Hernandez, 361-462-0078
South Central Calhoun County WCID 1	13774001	has single generator but is not enough to power the system, flow is to high. Sustained collection system damage. Cannot completely asses due to system being evacuated.	Calhoun	Bickley Powell, 361-746-0750
Tx Dept of Transportation	14619001	no power	Guadalupe	Ned Pyatt, 512-952-1840
US Army Corp of Engineers	12088001	lift station damaged	Washington	Randall McCartney, 979-596-1624